



EVERGREEN ENVIRO TESTING LLP

Address : Plot No. 047, 1st Floor, Block-F, Surajpur, Site-B, Industrial Area, Greater Noida, Gautam Buddha Nagar, U.P.- 201306

Ph. : 01204959379, 7428487870, Mob. : +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com

| | |
|-----------------------|-------------------------------------|
| Test Report No & Date | EETR/E/230524/010, DATE: 27.05.2024 |
|-----------------------|-------------------------------------|

ANALYSIS RESULT

| S. No. | Parameters | Results | Unit | Specification/ Limits As Per IS 10500:2012 | | Test Method |
|--------|----------------|---------|------------|--|-------------------|-------------|
| | | | | Requirement Limit | Permissible Limit | |
| 1. | E.Coli | <2 | MPN /100ml | <2 MPN /100ml | No Relaxation | IS:1622 |
| 2. | Total Coliform | <2 | MPN /100ml | <2 MPN /100ml | No Relaxation | IS:1622 |

Shivani
Checked by
SHIVANI PUNDIR



Evergreen Enviro Testing LLP
Surbhi
Issued By
Authorised Signatory
Surbhi Sharma

***End of the Report**

A. Manu
Manager
Nirmala Convent School
Shivpuri, Bulandshahr
203001 (U.P.)

Pooja
Principal
Nirmala Convent School
Shivpuri, Bulandshahr
203001 (U.P.)

Page 2 of 2

1. The result listed refer only to be Tested samples and applicable parameters.
2. Perishable samples will be destroyed after 15 days of sampling.
3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
4. Subject to Gr. Noida Jurisdiction.

An ISO 9001: 2015, ISO 14001.: 2015, 45001 : 2018 Environmental Laboratories