

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 473/dc1

Dated: 07/06/2024

It is certified that an inspection team headed by Dr. Pritam Singh (Name of Officers with designation) from Zila Panchyati Raj Adhikari, Bulandshahr PHED, Inspected the Nirmala Convent School, Shikarpur, Bypass Road, Near Om Farm House, Bulandshahr, U.P. 203001 (Name & Address of the school) on 07.06.2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. 581/ यो-7/22, dated- 28.05.2024 of Uttar Pradesh, Jal Nigam (Gramin) (PHED Lab) certified that the Nirmala Convent School, Shikarpur, Bypass Road, Near Om Farm House, Bulandshahr, U.P. 203001 (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till **One Year**

Signature with Seal : .....

Name : Dr. Pritam Singh  
जिला पंचायत राज अधिकारी

Designation : D.P.R.O.  
बुलन्दशहर

Name & Address of the Office / Department : .....

To  
Nirmala Convent School, Shikarpur,  
Bypass Road, Near Om Farm House,  
Bulandshahr, U.P. 203001  
(Name & Address of the Institution)

  
Principal  
Nirmala Convent School  
Shivpuri, Bulandshahr  
203001 (U.P.)

**Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies**



कार्यालय अधिशासी अभियन्ता खण्ड कार्यालय  
उ०प्र० जल निगम (ग्रामीण),  
विकास भवन द्वितीय तल-336 बुलन्दशहर

पत्रांक:- 581

/ पी-7

/ 22

दिनांक:- 28/05/2024

क्र०सं०	विकास खण्ड	ग्राम पंचायत का नाम	राजस्व ग्राम का नाम	स्थल का नाम	भौतिक परीक्षण				रासायनिक परीक्षण (पी० एम०)						
					पी० एम०	टी० डी० एस०	एनडिटी	रंग	क्लोराइड	समपूर्ण कठोरता	एल्कालिनिटी	आयन	नाइट्रेट	फ्लोराइड	डीएमए
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
		शिकारपुर वार्डपास रोड	शिकारपुर वार्डपास रोड	निर्मला कॉन्वेंट स्कूल	6.5-8.5	500-2000	0-5		250-1000	200-600	200-600	0.3-1.0	0-45	1-1.5	0.01-0.05
1	बुलन्दशहर	शिकारपुर वार्डपास रोड	शिकारपुर वार्डपास रोड	निर्मला कॉन्वेंट स्कूल	7.31	670	0.17	रमझिन	84	364	496	0.50	10.0	0.5	0.0



JE (Lab)

Principal

Nirmala Convent School  
Shivpuri, Bulandshahr  
203001 (U.P.)

AE (Lab)



# EVERGREEN ENVIRO TESTING LLP

Address : Plot No. 047, 1st Floor, Block-F, Surajpur, Site-B, Industrial Area, Greater Noida,  
Gautam Buddha Nagar, U.P. - 201306

Ph. : 01204959379, 7428487870, Mob. : +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com



## TEST REPORT

ISSUED TO	:	M/S NIRMALA CONVENT SCHOOL (AFFILIATED TO CBSE, NO. 2130021), KHASRA NO. 2116-2123, SHIKARPUR BY PASS ROAD, NEAR OM FARM HOUSE, BULANDSHAHR-203001, (U.P.)
Sample Identification No.	:	EETR/E/230524/010
Test Report No & Date	:	EETR/E/230524/010, DATE: 27.05.2024
Sampling Method	:	NA
Sample Description	:	Ground Water
Sample Collection Date	:	23.05.2024
Sample Collected by	:	Customer
Sampling Location	:	Borewell
Sample Quantity	:	2 +1 Ltr.
Date of Sample Received	:	23.05.2024
Sample Condition	:	OK
Analysis Duration	:	23.05.2024 To 27.05.2024

## ANALYSIS RESULT

S. No.	Parameters	Results	Unit	Specification/ Limits As Per IS 10500:2012		Test Method
				Requirement Limit	Permissible Limit	
1.	pH	7.74	---	6.5 - 8.5	No Relaxation	IS:3025(part-11)
2.	Colour	<1	Hazen	5.0 Max	15.0 Max	IS:3025(part-5)
3.	Odour	Agreeable	---	Agreeable	Agreeable	IS:3025(part-7)
4.	Turbidity	<1	NTU	1.0 Max	5.0 Max	IS:3025(part-10)
5.	Total Dissolved Solids	792	mg/L	500.0 Max	2000 Max	IS:3025(part-16)
6.	Total Hardness(as CaCO <sub>3</sub> )	296	mg/L	200 Max	600 Max	IS:3025(part-21)
7.	Chloride (as Cl)	89.4	mg/L	250 Max	1000 Max	IS:3025(part-32)
8.	Total Alkalinity(as CaCO <sub>3</sub> )	272	mg/L	200 Max	600 Max	IS:3025(part-23)
9.	Sulphate (as SO <sub>4</sub> )	94.2	mg/L	200 Max	400 Max	IS:3025(part-24)
10.	Residual free Chlorine	BDL(DL-0.1)	mg/L	0.2 Min	1.0 Max	IS:3025(part-26)
11.	Fluoride (as F)	BDL (DL-0.01)	mg/L	1.0 Max	1.5 Max	APHA24th Edn. (4500F,B)
12.	Calcium (as Ca)	68.9	mg/L	75 Max	200 Max	IS:3025(part-40)
13.	Magnesium (as Mg)	30.13	mg/L	30 Max	100 Max	IS:3025(part-46)
14.	Iron (as Fe)	BDL (DL-0.01)	mg/L	0.3 Max	No Relaxation	IS:3025(part-53)

BDL: Below Detection limit  
DL: Detection limit

Checked by  
**SHIVANI PUNDIR**



Principal  
Nirmala Convent School  
Shivpuri, Bulandshahr  
203001 (U.P.)

Evergreen Enviro Testing LLP  
Issued By  
Charan Kumar Singh

Page 1 of 2

- Note :
1. The result listed refer only to be Tested samples and applicable parameters.
  2. Perishable samples will be destroyed after 15 days of sampling.
  3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
  4. Subject to Gr. Noida Jurisdiction.



# EVERGREEN ENVIRO TESTING LLP

Address : Plot No. 047, 1st Floor, Block-F, Surajpur, Site-B, Industrial Area, Greater Noida,  
Gautam Buddha Nagar, U.P. - 201306

Ph. : 01204959379, 7428487870, Mob. : +91-8010087998, 9643079162, 7982197942

Email ID : evergreenlab03@gmail.com, info@evergreeneclab.com, Website : www.evergreeneclab.com

Test Report No & Date	EETR/E/230524/010, DATE: 27.05.2024
-----------------------	-------------------------------------

## ANALYSIS RESULT

S. No.	Parameters	Results	Unit	Specification/ Limits As Per IS 10500:2012		Test Method
				Requirement Limit	Permissible Limit	
1.	E.Coli	<2	MPN /100ml	<2 MPN /100ml	No Relaxation	IS:1622
2.	Total Coliform	<2	MPN /100ml	<2 MPN /100ml	No Relaxation	IS:1622

Checked by  
**SHIVANI PUNDIR**



Evergreen Enviro Testing LLP  
Issued By  
Authorised Signatory  
**Surbhi Sharma**

\*\*\*End of the Report\*\*

Principal  
**Nirmala Convent School**  
Shivpuri, Bulandshahr  
203001 (U.P.)

- Note :
1. The result listed refer only to be Tested samples and applicable parameters.
  2. Perishable samples will be destroyed after 15 days of sampling.
  3. This report cannot be used as evidence in the court of law and cannot be used in part or full in any media without prior permission.
  4. Subject to Gr. Noida Jurisdiction.